

## Energy use optimization

# SCOPE 2

- Set **OR temperature goal within a 18–22 °C** range, provided that hypothermia prevention measures (eg warming blankets, warming fluid devices) and monitoring are in place. **Newborns are excluded** from this recommendation
- **Burn Unit Operating theatre** optimum temperature range is 24°C to 30°C
- OR **relative humidity** should be maintained between 30% and 60% at all times
- **Theatre doors** and **hospital windows should be kept closed** at all times to reduce temperature loss
- **Scavenging systems** should be turned off at night and during weekends, except in designated ORs for emergent surgical procedures
- **Switch off** computers and Wi-Fi network during off-hours. Last person to leave the OR must turn off lights and computers that still remain operative
- Label equipment that can be **turned off safely after use**
- Please dispose **batteries** properly
- **Surgical hand rubbing** is preferred over surgical hand scrubbing
- **Close water tap** when it is not in use

Executive bundle to reduce your carbon footprint

